



SPORTON LAB.

Certificate No: EL332113

CERTIFICATE

● **EQUIPMENT: EMERGENCY DOOR RELEASE CALL POINT**
MODEL NO. : CP-15 Series, CP-20 Series, CP-21 Series, CP-22 Series,
CP-24 Series, CP-25 Series, CP-32 Series, CP-31 Series,
CP-34 Series

APPLICANT : GIANNI INDUSTRIES, INC.

No. 13, Zhongxing Road, Tucheng District,
New Taipei City 236, Taiwan (R.O.C.)




I HEREBY

CERTIFY THAT:

THE MEASUREMENTS SHOWN IN THIS TEST REPORT WERE MADE IN ACCORDANCE WITH THE PROCEDURES GIVEN IN **EUROPEAN COUNCIL DIRECTIVE 2004/108/EC**. THE EQUIPMENT WAS **PASSED** THE TEST PERFORMED ACCORDING TO

European Standard EN 55011:2009+A1:2010 Class B,
EN 61000-3-2:2006/A1:2009/A2:2009, EN 61000-3-3:2008 and
EN 61000-6-2:2005 (IEC 61000-4-2:2008,
IEC 61000-4-3:2006/A1:2007/A2:2010, IEC 61000-4-4:2004/A1:2010,
IEC 61000-4-5:2005, IEC 61000-4-6:2008,
IEC 61000-4-8:2009, IEC 61000-4-11:2004).

THE TEST WAS CARRIED OUT ON **Apr. 02, 2013** AT
SPORTON INTERNATIONAL INC. LAB.



Jack Deng

Engineering Manager