

Certificate of Assessment

No. 245 (Revision)

"Copyright CSIRO 2004 ©"
Copying or alteration of this report
without written authorization from CSIRO is forbidden.

We have examined the information submitted to us and appraised the suitability of the alternative items of hardware, in terms of Australian/New Zealand Standard 1905, Part 1-1997, for use with specific fire-rated doorsets, on behalf of

Trafalgar Building Products Pty Limited
21-25 Mitchell Road
BROOKVALE NSW

CSIRO Manufacturing and Infrastructure Technology's report FSV 0736 describes a fire test conducted to evaluate the alternative items of hardware.

PRODUCT NAME

& DESCRIPTION: MISCELLANEOUS: GEM GK-300 Series Electric Strike, made out of stainless steel.

CONCLUSION:

The fitting of the alternative items of hardware, to the previously tested doorsets as reported in Sponsored Investigation FSV 0609, is permissible within the terms of clause 4.1 of Australian Standard 1905, Part 1-1997. The doorsets listed in the table below would qualify for the fire-resistance level shown, if fitted with the alternative items of hardware.

ITEM OF HARDWARE	DOORSET REPORT	FIRE RESISTANCE LEVEL (FRL)
<u>MISCELLANEOUS:</u> GEM GK-300 Series Electric Strike	FSV 0609	-/240/30

Issued on the 12th day of January 2005 without alterations or additions.

This Certificate will expire on 31 January 2010.



Garry E Collins
Manager, Fire Testing and Assessments

THIS CERTIFICATE SUPERSEDES CERTIFICATE No. 245 ISSUED ON 1 FEBRUARY 2000.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



CSIRO Manufacturing & Infrastructure Technology

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555